

ADDENDUM NO. 4
21ST AVENUE SW PRESERVATION PROJECT
PROJECT #36253

ATTENTION ALL BIDDERS AND PLANHOLDERS: You are hereby notified that the Bid and Contract Documents are amended as follows:

A) CLARIFICATION

- 1) Per Special Provision 8-20.3(8)A Splices: "No splicing of traffic signal, service, or photo-electric/illumination node conductors shall be allowed." For clarification, the new conductors shown between the push button posts and the junction boxes will need to be run back to the traffic signal controller cabinet in order to avoid splicing.

B) BID OPENING

The Bid Due Date has not changed. It remains at Tuesday, 12-May-2026 at 2:00pm.

All bidders are required to acknowledge receipt of this addendum on page RFB-8 of the Bid Form. Failure to do so may cause rejection of the bid.

CITY OF FEDERAL WAY

Christine Mullen, P.E.
Engineering Manager