

ADDENDUM NO. 1

Federal Way-Panther Lake Supply Only Steel Truss Recreation Bridge

Bid Date: Tuesday, April 24, 2018, 2 PM PDT
Addendum Date: April 5, 2018
Sent From: City of Federal Way, Owner
Sent Via: David A. Clark Architects, PLLC

TO ALL PLANHOLDERS OF RECORD:

Notice is hereby given to all planholders of record on this date that the following Addendum shall supplement and supersede (if in conflict) all affected portions of the contract on the above referenced project.

Acknowledge the receipt of this Addendum. Failure to do so may subject the Bidder to disqualification.

All items shown in ~~strikeout~~ have been removed from the specifications or drawings and all items shown as underlined have been added to the specifications or drawings. Bold type is added for emphasis only.

SPECIFICATIONS:

1. **Section 132417-2.03- Dimensions and Loadings:**

A: Bridge dimensions: Bridge length = 50'

E: Live loads: 100 psf pedestrian load.

END OF ADDENDUM NO. 1